

X Entered

Electric Meter Report



Meter Base #	01214-E4
Meter Serial #	2007-0242294427
Service	
Fed From Meter #	AAHC19000586
(Base #)	08256-E8

Initial Installation Only
 Removal Only
 Replacement

Building	Conference Center East Addition (Solar)
Building #	1214
Today's Date	9/25/2020

Date Installed	9/25/2020
Date Removed	
Initial Reading KWH	0
Display Digits	5

Replacement/Removal Information

Serial # of old meter	NA
Final Reading KWH	NA
KW	NA
Report Submitted by:	Kevin Taylor

Transformer Information

KVA	1500
Primary Voltage	13800
Secondary Voltage	480/277

Fed from DC #	10
Fed from LC #	
Fed from SW #	101B

Demand Limit High Low

Meter Information

Manufacturer	Electro Industries
Type or Model	Shark 250
Form #	9S
K.H.	2.00159
Class	10
BAS System ID	

Service Voltage		Mechanical	
Connection Type		Solid State Programmed	x
		Solid State Non-programmable	
		IP Address	172.21.120.74
		Ethernet Jacks	HAP4-

CT/PT Information

CT Phase Ratio	100:5
CT Neutral Ratio	NA
# of CT's	3
Service Rating	

PT Ratio	1:1
Number of Voltages at Meter	3

Multiplier

Mechanical (PT X CT)	
Solid State Non-programmable (PT x CT)	40
Solid State Programmable	

DESCRIBE METER LOCATION Meter is in Electrical room on West side of Addition

Notes Meter is for the Solar panels on roof

Costs are the responsibility of: (name of contractor)

Route: Sequence: Date Entered: