

(LB) Medicine at UIUC Energy Report 2020

The purpose of this report is to:


*Provide Information concerning energy cost

*Track your energy utilization compared to prior periods

Campus Energy Utility Index (EUI) is calculated by deriving the total BTUs consumed by

College Comparison | Currently your college utilizes

49.41% MORE Energy than the Campus average.




net assignable square feet for vour college.	
EUI Rankings by UIUC Building Type	
Building Type	Avg of BTU_PER_SQFT
Recreation/Athletic Center/Gymnasium	335,758.78
Medical Office/Clinic	293,505.43
Laboratory	212,882.62
Classrooms/Educational/Library	174,547.77
Office	173,283.46
Dormitory/Ward	95,832.73
Source: F&S Energy Billing System	


CY_GSF 19,601.93 PY_GSF 66,592.84 % Change_GSF 70.56% LESS Gross Square Feet Then The Prior Year.

*The energy index combines natural gas (therms), chilled water (MBtu), Steam (Klbs), electricity (KWh) into a single measurement.

Comparing last year's usage to this year's usage you have utilized

82.35% LESS energy than the prior year.





Printed: 7/31/2020

Business Applications Database: Sourced from EBS and ARCHIBUS